


Test Verification of Conformity

Verification Number: 220500635HAN-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	CHAMPION POWER EQUIPMENT, INC. 12039 SMITH AVENUE, SANTA FE SPRINGS, CA 90670, USA
Product Description:	Low power generating sets
Ratings & Principle Characteristics:	50Hz, CosΦ=1,0, DC 12V, 8A Refer to Appendix
Models/Type References:	82001i-EU, 82001i-DF-EU, 82001i-SC, 82001i-DF-SC, 82001i-DE, 82001i-DF-DE, 82001i, 82001i-DF, 73001i-EU, 73001i-P-EU, 73001i-DF-EU, 73001i-SC, 73001i-P-SC, 73001i-DF-SC, 73001i-DE, 73001i-P-DE, 73001i-DF-DE, 73001i, 73001i-P, 73001i-DF, CPG4000DHY-EU, CPG4000DHY-DF-EU, CPG4000DHY-SC, CPG4000DHY-DF-SC, CPG4000DHY-DE, CPG4000DHY-DF-DE, CPG4000DHY, CPG4000DHY-DF, 82001i-UK, 82001i-DF-UK, 73001i-UK, 73001i-P-UK, 73001i-DF-UK, CPG4000DHY-UK, CPG4000DHY-DF-UK
Brand Name:	CHAMPION, CHAMPION POWER EQUIPMENT, CHAMPION GLOBAL POWER EQUIPMENT
Relevant Standards/Directives:	EN 55012:2007+A1:2009 EN IEC 61000-6-1:2019 the EMC directive (2014/30/EU)
Verification Issuing Office Name & Address:	Intertek Testing Services Zhejiang Ltd. Building No. 2, Juanhu Science and Technology Innovation Park, No. 500 Shuiyueting East Road, Haining City, Zhejiang Province, China
Date of Tests:	June 10, 2022 ~ June 18, 2022
Test Report Number(s):	180600468HZH-001+A1

Signature



Name: Leo Ye

Position: Manager

Date: April 04, 2023

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 220500635HAN-V1.

Model	Fuel type	Rated voltage	Rated power	Max. power	Parallel output power	Generator	Engine	Remote control	Weight
82001i-EU, 82001i-SC, 82001i-DE	Gasoline	220V	1,6kW	1,75kW	3,0kW	62 series	YF149FD	Without	21,0
82001i		230V							
82001i-DF-EU, 82001i-DF-SC, 82001i-DF-DE	Gasoline/ LPG	220V	1,6kW(G asoline)/ 1,44kW(LPG)		3,0kW(Ga soline)/ 2,75kW(L PG)		YF149FD -L_G		26,1
82001i-DF		230V							
73001i-EU, 73001i-SC, 73001i-DE	Gasoline	220V	3,2kW	3,4kW	6,0kW	83 series	YF170FD		38,0
73001i-P-EU, 73001i-P-SC, 73001i-P-DE									
73001i		230V						Without	38,0
73001i-P								With	43,7
73001i-DF-EU, 73001i-DF-SC, 73001i-DF-DE	Gasoline/ LPG	220V	3,2kW(G asoline)/ 2,88kW(LPG)		6,0kW(Ga soline)/ 5,45kW(L PG)		YF170FD -L_G	Without	44,0
73001i-DF		230V							

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

82001i-UK	Gasoline	240V	1,6kW	1,75kW	3,0kW	62 series	YF149FD	Without	21,0
82001i-DF-UK	Gasoline/ LPG		1,6kW (Gasoline) 1,44kW(L LPG)		3,0kW (Gasoline) / 2,75kW(L LPG)		YF149FD -L_G		26,1
73001i-UK	Gasoline		3,2kW	3,4kW	6,0kW	83 series	YF170FD		38,0
73001i-P-UK								With	43,7
73001i-DF-UK	Gasoline/ LPG		3,2kW (Gasoline) 2,88kW(L LPG)		6,0kW (Gasoline) / 5,45kW(L LPG)		YF170FD -L_G	Without	44,0
CPG4000DHY- UK	Gasoline		3,5kW	3,6kW	6,6kW	85 series	YF172IV		42,5
CPG4000DHY- DF-UK	Gasoline/ LPG		3,5kW (Gasoline) 3,15kW(L LPG)		6,6kW (Gasoline) / 5,95kW(L LPG)		YF172IV- L_G		42,6

Signature



Name: Leo Ye

Position: Manager

Date: April 04, 2023

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.